

**Assistant Executive Engineer PWD (Retd)**  
**Member (Structural Engineer)**  
**Heritage Screening Committee**  
**HR & CE Dept. Villupuram Region**  
**Chartered Engineer / Approved Valuer**  
**Class 1.A. Registered Engineer**

Date : .....

## TAMIL NADU PUBLIC BUILDINGS (LICENSING) RULES, 1966

## THE SCHEDULE

**FORM A**

05/2020

[Form of application under sub-section (1)/ sub-section (2) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act XIII of 1965) referred to in rules 3 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.

From,

**V.K.Palaniappan,**  
**Holy Angel School CBSE,**  
Correspondent  
Reddiyar Street (West),  
Rettanai. 604 306.  
Tindivanam Taluk,  
Villupuram District.

To

The Tashildar,  
Tindivanam Taluk,  
Tindivanam,  
Villupuram District.

Sir,

1. I intended to continue to use the existing public building which is situated in the site for Reddiyar Street (West), S.F.113/3,113/5,113/6,113/7B. Rettanai. 604306. Tindivanam Taluk, Villupuram District and specified in the Statement enclosed as a public building for a period of 3 years from **01.06.2020 to 31.05.2023** including of both dates.

2. The year of construction and the present approximate cost of construction and the purpose for which it is to be used or is being used as Public building are also furnished in the statement accompanying this application.

3. I enclose a challan for Rs.....

4. I also enclose a certificate of structural soundness in the prescribed form furnished by the Engineer Thiru. Er. G. VIJAYAKUMARAN, Registration No. Class - 1A of Villupuram district.

Date

Signature of the Applicant

Enclosures: (1) Statement.

(2) Chalan for Rs..... towards the application fee.

Plot No.41/42, Sampth Nagar, Palam Pet, Chetpet, Chetpet Tk., Thiruvannamalai District,  
Plot No.172, M.G.R.Street, Kurinji Nagar, Semmandalam, Cuddalore - 607 001. E-mail : vk.premisri@gmail.com  
(Engineer to issue structural soundness Certificate to Public Buildings Under Public Building Licensing Act for  
Villupuram, Cuddalore, Thiruvannamali, Kanchipuram & Chennai Districts)

Assistant Executive Engineer PWD (Retd)  
 Member (Structural Engineer)  
 Heritage Screening Committee  
 HR & CE Dept. Villupuram Region  
 Chartered Engineer / Approved Valuer  
 Class 1.A. Registered Engineer

Date : 12.03.2020

**Certificate of Structural Soundness for the Public Buildings**  
**Statement accompanying Form - A**

1.	Name of the Owner/Project	V.K PALANIAPPAN. HOLY ANGEL SCHOOL (CBSE)
2	Location (Street number, Ward number, name of place, i.e. Corporation/ Municipality/ Panchayat/ Panchayat Union/ Township/ Cantonment) i. Plot No/Door No ii. Survey No iii. Village iv. Municipal Limit	Reddiyar Street (West) S.F.113/3,113/5,113/6,113/7B. Rettanai. 604 306. Tindivanam Taluk, Villupuram District
b	a) Year of construction b) Age of the Building	2017 04 Years
4.	Approximate cost of construction as per current rates	Rs:3,40,00,000.(Rupees Three Crores and forty lakhs Only)
5.	Purpose for which the building is being used or proposed to be used	Educational Institutions,
s6.	Purpose for which the building has hitherto been used	Conducting Classes for grade I to XII <sup>TH</sup> Std
7.	Details of construction of the building (particulars of the foundation soil, specification of the various parts under-	
	(1) Foundation	RCC Isolated Footing
	(2) Basement	Brick Masonry with cement mortar 3 feet above Road level
	(3) Superstructure	Framed Structure with Brick Work in Cement mortar, RCC Roof,
	(4) Joineries	Steel Doors & Windows
	(5) Roof Floor Finish	R.C.C. Roof Cement Mortor flooring/Vitrified Tiles.

Plot No.41/42, Sampth Nagar, Palam Pet, Chetpet, Chetpet Tk., Thiruvannamalai District,  
 Plot No.172, M.G.R.Street, Kurinji Nagar, Semmandalam, Cuddalore - 607 001. E-mail : vk.premisri@gmail.com  
 (Engineer to issue structural soundness Certificate to Public Buildings Under Public Building Licensing Act for  
 Villupuram, Cuddalore, Thiruvannamali, Kanchipuram & Chennai Districts)



Assistant Executive Engineer PWD (Retd)  
Member (Structural Engineer)  
Heritage Screening Committee  
HR & CE Dept. Villupuram Region  
Chartered Engineer / Approved Valuer  
Class 1.A. Registered Engineer

Date : 12/03/2020

	(6) AREA DETAILS 1. Total Area of site 2. Build Up Area i) G.F - RCC ii) F.F - RCC iii) 2 <sup>nd</sup> F -RCC iv) Head Room v) Toilet Block 3.Total Build Up Area	603.88 Sq.m (6500.11 S.ft) 603.88 Sq.m (6500.11 S.ft) 603.88 Sq.m (6500.11 S.ft) 59.70 Sq.m (642.61 S.ft.) 111.48 Sq.m (1200.00 S.ft) 1982.82 Sq.m (21342.94S.ft.)
8.	Period for which license is required	01.06.2020 to 31.05.2023 Subject to the Natural calamities.
9.	Number of persons to be accommodated	1500 Persons.(One Thousand and Five hundred including Students & Staffs Only)

Certified that I have inspected the site on 12.03.2020 and declare that the proposed building is structurally sound as per plan to be used as a Public Purpose building.

Certified that no addition or alteration has been made to the existing building or portion of a building, Reddiyar Street (West),S.F.113/3,113/5,113/6,113/7B.Rettanai. 604 306.Tindivanam Taluk,Villupuram District which this application has been made.

I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or a portion of the building originally is changed or altered subsequently.

Date: 12.03.2020

Signature of the Applicant

Signature of the Registered Engineer

B.E., M.B.A., M.I.E., F.I.V.,

Chartered Engineer / Approved Valuer  
Registered Engineer (Class 1.A)  
Under Public Buildings Licencing Act  
Authorised Engineer to issue structural  
soundness certificate to public buildings for  
Cuddalore, Villupuram, Tiruvannamalai,  
Kancheepuram & Chennai Districts.

Plot No. 172, M.G.R. Street,  
Kurinji Nagar, Semmandalam,  
Cuddalore - 607 001.  
Mobile : 9443043295

Plot No.41/42, Sampth Nagar, Palam Pet, Chetpet, Chetpet Tk., Thiruvannamalai District,  
Plot No.172, M.G.R.Street, Kurinji Nagar, Semmandalam, Cuddalore - 607 001. E-mail : vk.premisri@gmail.com

(Engineer to issue structural soundness Certificate to Public Buildings Under Public Building Licensing Act for  
Villupuram, Cuddalore, Thiruvannamali, Kanchipuram & Chennai Districts)

Assistant Executive Engineer PWD (Retd)  
Member (Structural Engineer)  
Heritage Screening Committee  
HR & CE Dept. Villupuram Region  
Chartered Engineer / Approved Valuer  
Class 1.A. Registered Engineer

Date : 12/03/2020

**FORM B**

(Form of certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act, 1965  
(Tamil Nadu Act 13 of 1965) referred in rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.]

I certify that I have inspected the **School building for Holy Angel School CBSE, Reddiyar Street (West), S.F.113/3,113/5,113/6,113/7B. Rettanai. 604 306. Tindivanam Taluk, Villupuram District** mentioned in the statement and furnish below its salient technical features:

**(1) Foundation-**

- (i) Depth below ground level : 2.10 M (Average)  
(ii) Nature of soil met with at foundation level. : Red Earth Mixed With Sand  
(iii) Pressure at foundation. : 10.00 M. Ton/Sq.m  
(iv) Probable safe bearing capacity of the strata met with at foundation. : 15.00 M. Ton/Sq.m

**(2) Superstructure-**

- (i) Maximum stress in the most critical Section of masonry and concrete. : R.C .C. 1: 2 : 4 - 65 Kg/Cm<sup>2</sup>  
(ii) Nature of masonry and concrete and its safe permissible stress. : R.C .C. 1: 2 : 4 - 100 Kg/Cm<sup>2</sup>  
: Brick masonry with C.M. -30 Kg/Cm<sup>2</sup>

The structural soundness of the building has been verified by me on 12.03.2020 with reference to I.S.I. loading standards 875 (Latest version) and other relevant Indian Standards Code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period from the 01.06.2020 to 31.05.2023 inclusive.

Date. 12.03.2020

Signature of the Engineer with Seal

**G.VIJAYAKUMARAN**

B.E., M.B.A., M.I.E., F.I.V.,

Chartered Engineer / Approved Valuer  
Registered Engineer (Class 1.A)  
Under Public Buildings Licensing Act  
Authorised Engineer to issue structural  
soundness certificate to public buildings for  
Cuddalore, Villupuram, Tiruvannamalai,  
Kancheepuram & Chennai Districts.

Plot No. 172, M.G.R. Street,  
Kurinji Nagar, Semmandalam,  
Cuddalore - 607 001.  
Mobile : 9443043295

Plot No.41/42, Sampth Nagar, Palam Pet, Chetpet, Chetpet Tk., Thiruvannamalai District,  
Plot No.172, M.G.R.Street, Kurinji Nagar, Semmandalam, Cuddalore - 607 001. E-mail : vk.premisri@gmail.com  
(Engineer to issue structural soundness Certificate to Public Buildings Under Public Building Licensing Act for  
Villupuram, Cuddalore, Thiruvannamali, Kanchipuram & Chennai Districts)



**Er. G. VIJAYAKUMARAN**

B.E., M.B.A., M.I.E., F.I.V.,

Assistant Executive Engineer PWD (Retd)  
Member (Structural Engineer)  
Heritage Screening Committee  
HR & CE Dept. Villupuram Region  
Chartered Engineer / Approved Valuer  
Class 1.A. Registered Engineer

Cell : 94430 43295


Date : ..... 12.03/2020

**FORM - C**

**STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

1	Location of the building - Door number, street and name of the place i) Plot No/Door No ii) Survey No iii) Village iv) Municipal Limit	<b>Holy Angel School CBSE,</b> Reddiyar Street (West) S.F.113/3,113/5,113/6,113/7B. <b>Rettanai. 604 306.</b> Tindivanam Taluk, Villupuram District
2	Age of building	04 Years
3	The value of the building at the current rates	Rs:3,40,00,000.(Rupees Three Crores and forty lakhs Only)
4	Number of storey's	G.F., F.F & 2 <sup>nd</sup> Floor only,
5	Short description of structures- Steel RC framed of load bearing masonry.	Framed Structure with Brick Work in cement Mortar.
6	Purpose for which the building is certified for use.	Conducting Classes for grade I to XII <sup>TH</sup> Std
7	The period for which the building will be structurally sound	<b>01.06.2020 to 31.05.2023</b> Subject to the Natural calamities.
8	Number of persons to be accommodated	<b>1500</b> Persons.(One Thousand and Five hundred including Students & Staffs Only)
9	Remarks	1.The Buildings are structurally sound stable strong and fit for habitation. 2. Periodical Maintenance to be Carried out regularly

Date. 12.03.2020

  
Signature of the Engineer M. A. S Seal  
B.E., M.B.A., M.I.E., F.I.V.,  
Chartered Engineer / Approved Valuer  
Registered Engineer (Class 1.A)  
Under Public Buildings Licencing Act  
Authorised Engineer to issue structural  
soundness certificate to public buildings for  
Cuddalore, Villupuram, Tiruvannamalai,  
Kancheepuram & Chennai Districts.

Plot No. 172, M.G.R. Street,  
Kurinjil Nagar, Semmandalam,  
Cuddalore - 607 001.  
Mobile : 9443043295

Plot No.41/42, Sampth Nagar, Palam Pet, Chetpet, Chetpet Tk., Thiruvannamalai District,  
Plot No.172, M.G.R.Street, Kurinji Nagar, Semmandalam, Cuddalore - 607 001. E-mail : vk.premisri@gmail.com

(Engineer to issue structural soundness Certificate to Public Buildings Under Public Building Licensing Act for  
Villupuram, Cuddalore, Thiruvannamalai, Kanchipuram & Chennai Districts)

## FORM - D

### FORM OF LICENCE UNDER SUB SECTION OF SECTION 6 OF THE MADRAS PUBLIC BUILDING (LICENSING) ACT 1965 (MADRAS ACT 1965) REFERRING TO RULE 6 OF THE MADRAS PUBLIC BUILDING LICENSING RULES 1965.

### LICENCE


Licence No.05 /2020

Fees Rs.1000/-


LICENCE is hereby granted to the Correspondent, Holy Angel CBSE School, Rettanai Village, Tindivanam Taluk, Viluppuram District for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned hereunder.

The period of validity of the Licence shall be from 01.06.2020 to 31.05.2023 (3 years).

<i>Location of the Building Door No / Street and Name of the place</i>	<i>Purpose for which the Building is licenced to be used as a public Building</i>	<i>No. of Persons to be Accommodated</i>
R.S.No.113/3, 113/5, 113/6, 113/7B Rettanai Village, Tindivanam Taluk, Viluppuram District.	For conducting class rooms From 1 <sup>st</sup> Std to XII <sup>th</sup>	1500



98  
12/6/2020

  
Signature of the Competent Authority,  
and Tahsildar, Tindivanam.



**Er.G.VIJAYAKUMARAN**

B.E.,M.B.A.,M.I.E.,F.I.V.,

Assistant Executive Engineer PWD (Retd)  
Member (Structural Engineer)  
Heritage Screening Committee  
HR & CE Dept. Villupuram Region  
Chartered Engineer / Approved Valuer  
Class 1.A. Registered Engineer

Cell : 94430 43295

Date : 12.03.2020

**FORM E**

[Form of report to be made to the competent authority by inspecting authorities or officers appointed under other Acts under section 28 of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act XIII of 1965) referred to in rule 7 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.]

1. Name and designation of Inspecting officer : Er.G. VIJAYAKUMARAN,  
B.E., M.B.A., M.I.E., F.I.V.,  
Chartered Engineer / Approved Valuer,  
Class 1.A. Registered Engineer,  
Plot No.172, M.G.R. Street,  
Kurinji Nagar, Semmandalam,  
Cuddalore - 607 001.
2. Location of the building inspected : **Holy Angel School CBSE,**  
i) Door No Street : Reddiyar Street (West),  
ii) Survey No : S.F.113/3,113/5,113/6,113/7B.  
iii) Village : **Rettanai. 604 306.**  
iv) Taluk/District : Tindivanam Tk, Villupuram District
3. Date of inspection. : 12.03.2020
4. Purpose for which the building is Used : Conducting Classes for grade I to XII<sup>th</sup>
5. Nature of defects noticed. : Nil
6. Suggestions for rectifying defects. : Nil
7. If in a dangerous condition, Immediate steps recommended to be taken. : Nil

**Note:**

1. This Certificate covers only the Buildings mentioned there in not any other buildings in premises.
2. Maintenance of the above building should be made periodically.
3. If the certificate is tampered illegally or made corrections/alternations without permission.
4. This certificate never and out-scope of any natural disasters like earthquake, cyclone fire and any other impacts which affects the stability of the buildings mentioned in this Certificate.
5. Any cracks developing in the structure in at the above said period should be brought to the notice of the certifying engineer.

**G.V. VIJAYAKUMARAN**  
B.E., M.B.A., M.I.E., F.I.V.,

Chartered Engineer / Approved Valuer  
Registered Engineer (Class 1.A)  
Under Public Buildings Licensing Act  
Authorised Engineer to issue structural  
soundness certificate to public buildings for  
Cuddalore, Villupuram, Tiruvannamalai,  
Kancheepuram & Chennai Districts.

Plot No. 172, M.G.R. Street,  
Kurinji Nagar, Semmandalam,  
Cuddalore - 607 001.  
Mobile : 9443043295

Plot No.41/42, Sampth Nagar, Palam Pet, Chetpet, Chetpet Tk., Thiruvannamalai District,  
Plot No.172, M.G.R.Street, Kurinji Nagar, Semmandalam, Cuddalore - 607 001. E-mail : vk.premisri@gmail.com

(Engineer to issue structural soundness Certificate to Public Buildings Under Public Building Licensing Act for Villupuram, Cuddalore, Thiruvannamali, Kanchipuram & Chennai Districts)